

# CERTIFICATE

Certificate No.: PL 4600753 009  
Project No.: 89218461

**Holder:** Estillon B.V.  
Linie 25  
5405 AR UDEN  
The Netherlands

**Product** : **Underlayment: Duralay Silentfloor Plus 3 mm**  
Total thickness : 3 mm  
Total mass : 2204 gr/m<sup>2</sup>

Certified in combination with : Floorcovering: 7 mm click laminate

On basis of the results of the tests specified below, we declare that the above specimen fulfils the requirements of the TÜV Rheinland Testmark **Noise Reduction** including **Regular Product Surveillance**. TÜV Testmark and Underlayments, Test Protocol Impact Sound – 2017 EV


NB: This certificate itself shall not be considered as a type examination certificate.

Performance properties	Requirement	Result
Impact sound improvement according ISO 10140 and ISO 717-2	$\geq 10 \text{ dB } \Delta L_{\text{lin}}$	Pass

Full details of the results can be found in the following report(s):

Reference	Date of issue	Result
Initial test report: A3925-3-RA-001	07-12-2020	10 dB $\Delta L_{\text{lin}}$ & 21 dB $\Delta L_{\text{w}}$

Arnhem, 09-03-2021

  
R. de Jonge, Managing director  
Page 1 of 1